

SEP-1167/17

Essen, 22.06.2018

Certificate

Applus⁺ RTD IWEX AUT System

We herewith certify that the IWEX AUT System of

Applus⁺ RTD b.v.
Delftweg 144
3046 NC Rotterdam (Netherlands)

satisfies the requirements based on VGB-ENIQ-Guideline VGB-R-516 second edition 2010.

The scope of this qualification encompasses welded joints in circumferential seams on pipelines made of low-alloyed steel with the following dimensions and with the following limits on the test conditions:



Diameter starting at 6" and wall thicknesses of 5 mm to 42 mm.
Surface temperature of the pipeline from 0 °C to 80 °C.

Our report SEP-1167/17 of 22.06.2018
on the qualification of the IWEX AUT System are binding.

The authorized inspector
of TÜV NORD Systems GmbH & Co. KG


C. Engel


The authorized inspector
of TÜV NORD Systems GmbH & Co. KG


D. Niekamp


Sitz der Gesellschaft
TÜV NORD Systems GmbH & Co. KG

Große Bahnstraße 31
22525 Hamburg

Tel.: 040 8557-0
Fax: 040 8557-2295
info@tuev-nord.de
www.tuev-nord.de

TÜV NORD GROUP

Vorsitzender des Aufsichtsrates
Dr. Dirk Stenkamp

Amtsgericht Hamburg
HRA 102137
USt.-IdNr.: DE 243031938
Steuer-Nr.: 27/628/00031

Komplementär
TÜV NORD Systems
Verwaltungsgesellschaft mbH, Hamburg

Amtsgericht Hamburg
HRB 88330

Geschäftsführer
Dr. Ralf Jung (Vorsitzender)
Silvio Konrad
Ulf Theike

Commerzbank AG, Hamburg
BIC (SWIFT-Code): COBADEFFXXX
IBAN-Code: DE 73 2004 0000 0405 6222 00

Deutsche Bank, Hannover
BIC (SWIFT-Code): DEUTDE2HXXX
IBAN-Code: DE 90 2507 0070 0026 3640 00

